



Test report - akumulator żelowy VIPOW 12V 7.0Ah

№:2014070904

Item No	12V7AH	Production Date	2014-7-9	Test Q'TY	100	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.04~13.11			Pass
3	sdsdDimension (±2mm)	L: 151 W: 65 H: 94 Th: 100	151*65*94*100			Pass
4	20hours rate	0.35A discharge T≥19.5H	20H23"48			Pass
5	27min	7A discharge T≥27min	36"14	35"51		Pass
6	3C	21A discharge T≥7min	8"49	8"35		Pass
7	Weight(kg)		2.09	2.08	2.10	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109